


Technological Process Perfection for Biomass Power Plant

DWEEN Boiler



01

Basic Package

Basic Package

<p>01 Boiler System Data Collection Module</p> <p>Installation and configuration of data collection equipment Dween Data Hub in the client-specific environment.</p> <p>Real-time collection of boiler technological parameters from the existing system.</p> <p>Real-time data are stored for one calendar year.</p>	<p>02 Data Visualization Module</p> <p>Data visualized in separate Dween Dashboard sections.</p> <p>Data visualized in SCADA components representing the client's physical system, graphs, charts,</p> <p>Data visualization is freely configurable and can be customized according to each Client's needs.</p> <p>Possible Dween Dashboard access rights configuration for individual users.</p>	<p>03 Boiler Energy Balance Calculation in Real-Time Module</p> <p>Calculation of primary air mass flow.</p> <p>Calculation of secondary air mass flow.</p> <p>Calculation of recirculating mass flow.</p> <p>Calculation of smoke mass flow into the chimney.</p> <p>Mass balance.</p> <p>Energy balance.</p> <p>Calculation of fuel supply rate and layer.</p> <p>Calculation of the secondary and primary air ratio.</p>	<p>04 Control Module</p> <p>Calculated optimal control recommendations (Set Points) provided to the operator via Dween Dashboard or email.</p> <p>Recommendations are tailored for every hour of boiler operation according to required control parameters.</p>	<p>05 Reporting Module</p> <p>Calculation and visualization of daily/weekly/monthly indicators:</p> <ul style="list-style-type: none">• Boiler efficiency, %• Economizer efficiency, %• System efficiency, %• Biomass consumption in MWh and tons• Cost of energy production in Eur/MWh and Eur/toe• Electricity consumption, kWh/MWh thermal• Energy prime cost, toe/MWh• Biomass calorific value MJ/and water content %• Excess air coefficient variation over time, % <p>Preparation of a user interface for entering biomass and electricity prices.</p> <p>Reports with boiler efficiency indicators are sent to responsible individuals daily, weekly, monthly.</p> <p>The format of reports is easily configurable and can be adapted according to each client's needs.</p> <p>Reports are sent to easily configurable email addresses.</p> <p>Reports are stored in the database for six months.</p>	<p>06 Notifications Module</p> <p>Operators receive notifications via email or SMS with an action prompt as soon as a deviation is detected.</p> <p>Deviations are freely configurable and can be customized according to each Client's needs.</p>	<p>07 Boiler Flue Gas Heat Exchanger Cleaning Recommendations</p> <p>An algorithm is prepared that calculates the efficiency of the boiler flue gas heat exchangers' heat transfer.</p> <p>Results are presented in a separate Dween Dashboard.</p> <p>Results are continuously monitored, and staff are informed about the need for cleaning when the heat transfer efficiency falls below the set threshold.</p> <p>Prediction of cleaning needs.</p>
---	---	---	---	--	--	---

Basic Package


01

Boiler System Data Collection Module

Installation and configuration of data collection equipment Dween Data Hub in the client-specific environment.

Real-time collection of boiler technological parameters from the existing system.

Real-time data are stored for one calendar year.



Basic Package

02

Data Visualization Module

Data visualized in separate Dween Dashboard sections.

Data visualized in Dween components representing the client's physical system, graphs, charts.

Data visualization is freely configurable and can be customized according to each Client's needs.


Possible Dween Dashboard access rights configuration for individual users.

Kuro parametrai	
Kuro rodiklis	92.95 kgne/MW
Kuro rodiklis	0.30 trn/MW
Kuro kiekis, degantis pakuroje	5.66 trn/h
Kuro drėgmė	26.82 %
Šilumos kiekis su kuru	20.52 MW
Kuro apatinis šilumingumas	3.63 MW/°C
	11.12 kg/h 86.87 %

Katilo parametrai	
Katilo galia (state estimator)	18.98 MW
Katilo galia (pagal matavimus)	18.98 MW
NVK katilo	92.50 %
NVK katilo (sausas kuras)	88.12 %
NVK katilo su DKE	105.22 %
Katilo log_dt	454.09 °C
Katilo šilumos perdavimo koef.	42.16 kW/°C

DKE parametrai	
DKE galia	2610.07 kW
DKE srautas	459.21 m³/h
Paduodama temp.	44.84 °C
Grįžtama temp.	39.84 °C
DKE log_dt	36.71 °C
DKE šilumos perdavimo koef.	71.09 kW/°C
Galių santykis su katilu	0.14

Suminis oro kiekis į pakurą	33.56 trn/h
Šilumos kiekis su oru	0.07 MW
Oro pertekliaus koef.	1.35



Basic Package

02


Data Visualization Module

Data visualized in separate Dween Dashboard sections.

Data visualized in Dween components representing the client's physical system, graphs, charts.

Data visualization is freely configurable and can be customized according to each Client's needs.

Possible Dween Dashboard access rights configuration for individual users.



Basic Package

02


Data Visualization Module

Data visualized in separate Dween Dashboard sections.

Data visualized in Dween components representing the client's physical system, graphs, charts.

Data visualization is freely configurable and can be customized according to each Client's needs.

Possible Dween Dashboard access rights configuration for individual users.




Basic Package

03

Boiler Energy Balance Calculation in Real-Time Module

- Calculation of primary air mass flow.
- Calculation of secondary air mass flow.
- Calculation of recirculating mass flow.
- Calculation of smoke mass flow into the chimney.
- Mass balance.
- Energy balance.
- Calculation of fuel supply rate and layer.
- Calculation of the secondary and primary air ratio.



Basic Package

04



Control Module

Calculated optimal control recommendations (Set Points) provided to the operator via Dween Dashboard or email.

Recommendations are tailored for every hour of boiler operation according to required control parameters.

Valdymo parametrai

	Esami	Rekomenduojami
Trauka, kai galingumas 0%	30.00 Pa	30.00 Pa
Trauka, kai galingumas 100%	53.00 Pa	53.00 Pa
I oro kiekis kai galingumas 0%	65.00 Pa	65.00 Pa
I oro kiekis kai galingumas 25%	70.00 Pa	70.00 Pa
I oro kiekis kai galingumas 50%	75.00 Pa	75.00 Pa
I oro kiekis kai galingumas 75%	78.00 Pa	80.00 Pa
I oro kiekis kai galingumas 100%	85.00 Pa	85.00 Pa
Dūmų recirkuliacija	49.07 Hz	49.67 Hz
I oro slėgis į pakurą	7319.18 Pa	6942.60 Pa
Maitintuvų greitis kai galingumas 100%	88.00 %	88.00 %



Basic Package

05

Reporting Module

Calculation and visualization of daily/weekly/monthly indicators:

- Boiler efficiency, %
- Economizer efficiency, %
- System efficiency, %
- Biomass consumption in MWh and tons
- Cost of energy production in Eur/MWh and Eur/toe
- Electricity consumption, kWh/MWh thermal
- Energy prime cost, toe/MWh
- Biomass calorific value MJ/and water content %
- Excess air coefficient variation over time, %


Preparation of a user interface for entering biomass and electricity prices.

Reports with boiler efficiency indicators are sent to responsible individuals daily, weekly, monthly.

The format of reports is easily configurable and can be adapted according to each client's needs.

Reports are sent to easily configurable email addresses.

Reports are stored in the database for six months.



Basic Package

05

Reporting Module

Generation of PDF reports

The screenshot displays a web application interface for generating PDF reports. The main content area shows a report titled "Ataskaita" for the period "2023-11-15 00-00.pdf". The report includes a table of "Suminiai paros duomenys" (Daily Summary Data) and "Vidutiniai paros duomenys" (Average Daily Data).

Date	Pagamintas šilumos kiekis per parą, MWh	Sunaudotas kuro kiekis per parą, MWh(k)	Biokuro suvartojimas per parą, tn	Atvežtas kuras. Suma per dieną, tn	Integruota kuro pauzė (1 d, 1/s)
2023-11-11	148.27	202.73	87.19	0.00	0.26
2023-11-12	133.27	179.88	75.43	0.00	0.22
2023-11-13	157.61	224.56	106.59	133.36	0.30
2023-11-14	159.15	218.64	106.48	130.38	0.31
2023-11-15	50.25	67.72	30.69	-	0.08

Date	Vidutinė galia per parą, MW	Vidutinės kuro sąnaudos per valandą, tn/h	Vidutinis paros NVK, %	Vidutinis kuro šilumingumas (dien.), MW/tn	Vidutinis drėgmės kiekis kure (dien.), %	Vid. drėgmės kiekis kure, pagal kuro tankį (d), %	Vid. drėgmės kiekis kure, laboratorijos (d), %
2023-11-11	6.51	3.77	72.76	2.38	48.11	-	-
2023-11-12	5.37	3.03	73.69	2.42	47.46	-	-
2023-11-13	6.47	4.32	71.67	2.24	50.37	39.97	-
2023-11-14	6.60	4.40	73.19	2.10	52.78	39.17	-
2023-11-15	6.26	3.81	75.07	2.24	50.50	-	-

Rytinė pamaina (07:00)

Date	Pamainos NVK, %
2023-11-14 07	71.86
2023-11-14 08	-
2023-11-14 09	-
2023-11-14 10	-
2023-11-14 11	-
2023-11-14 12	-
2023-11-14 13	-
2023-11-14 14	-
2023-11-14 15	-

Naktinė pamaina (19:00)

Date	Pamainos NVK, %
2023-11-14 18	-
2023-11-14 19	75.05
2023-11-14 20	-
2023-11-14 21	-
2023-11-14 22	-

Basic Package

05

Reporting Module

Calculation and visualization of daily/weekly/monthly indicators:

- Boiler efficiency, %
- Economizer efficiency, %
- System efficiency, %
- Biomass consumption in MWh and tons
- Cost of energy production in Eur/MWh and Eur/toe
- Electricity consumption, kWh/MWh thermal
- Energy prime cost, toe/MWh
- Biomass calorific value MJ/and water content %
- Excess air coefficient variation over time, %


Preparation of a user interface for entering biomass and electricity prices.

Reports with boiler efficiency indicators are sent to responsible individuals daily, weekly, monthly.

The format of reports is easily configurable and can be adapted according to each client's needs.

Reports are sent to easily configurable email addresses.

Reports are stored in the database for six months.



Basic Package

05

Reporting Module

Calculation and visualization of daily/weekly/monthly indicators:

- Boiler efficiency, %
- Economizer efficiency, %
- System efficiency, %
- Biomass consumption in MWh and tons
- Cost of energy production in Eur/MWh and Eur/toe
- Electricity consumption, kWh/MWh thermal
- Energy prime cost, toe/MWh
- Biomass calorific value MJ/and water content %
- Excess air coefficient variation over time, %


Preparation of a user interface for entering biomass and electricity prices.

Reports with boiler efficiency indicators are sent to responsible individuals daily, weekly, monthly.

The format of reports is easily configurable and can be adapted according to each client's needs.

Reports are sent to easily configurable email addresses.

Reports are stored in the database for six months.



Basic Package

06 Notifications Module

Operators receive notifications via email or SMS with an action prompt as soon as a deviation is detected.

Deviations are freely configurable and can be customized according to each Client's needs.

The screenshot displays the Notifications Module interface. At the top, there is a navigation bar with tabs for different system components: BVŠK-4 Katilas, Valdymas, BVŠK-4 Ventilatoriai, BVŠK-4 Eko, BVŠK-4 Vandens traktas, BVŠK-4 Elektra, BVŠK-4 Projektinės vertės, BVŠK-4 ataskaita, Pranešimai, and PdM. The 'Pranešimai' tab is currently selected.

Below the navigation bar, there are two tabs: 'Alerts' (selected) and 'Silences'. The main area shows a list of alerts. Each alert entry includes a timestamp, a description of the deviation, and associated tags. For example, one alert is: '2023-11-15 16:29:00|BVŠK1|smoke_vent_rec_rotation_frequency| Dabartinės vertės [44.0] nuokrypis nuo [75.0] yra didesnis nei [20] %, dabartinis nuokrypis [41.3] %'. This alert has tags for 'bvsk1' and 'operacijos r...' and a tag for 'smoke_vent_r...'. There are also '+' and refresh icons for each alert.

Another alert is: '2023-11-15 16:10:00|GK7|excess_air_coefficient_after_economizer| Dabartinės vertės [-9633.0] nuokrypis nuo [1.5] yra didesnis nei [20] %, dabartinis nuokrypis [656790.4] %'. This alert has tags for 'gk7' and 'operacijos r...'. There are also '+' and refresh icons for this alert.

Basic Package

07

Boiler Flue Gas Heat Exchanger Cleaning Recommendations


An algorithm is prepared that calculates the efficiency of the boiler flue gas heat exchangers' heat transfer.

Results are presented in a separate Dween Dashboard.

Results are continuously monitored, and staff are informed about the need for cleaning when the heat transfer efficiency falls below the set threshold.

Prediction of cleaning needs.

Decrease in heat transfer efficiency



Increased heat transfer efficiency after cleaning



Advanced Package

08

Automatic Control Module

Calculated optimal control recommendations (Set Points) are sent directly into the control system without human intervention.

Recommendations are sent at needed frequency for the required control parameters.

09

Water/Steam Cycle Balance Calculation Module

An algorithm is prepared that calculates the balance of the boiler water system, evaluating returning condensate, prepared water, tank level fluctuations, and produced steam.

Balance results are available in a separate Dween Dashboard.

Balance results are continuously monitored, and staff are informed via email or SMS about any deviation that would indicate equipment malfunction.

10

Boiler Long-Term Performance Monitoring Module

An algorithm is prepared calculating the efficiency of heat transfer across surfaces (reduced boiler efficiency).

An algorithm is prepared evaluating the deterioration of hydraulic pipeline properties

11

Boiler Operation Availability Module

Based on agreed terms, the operating status of the boiler, turbine, economizers (operating/not operating) is tracked.

Operation status reports for the day, month, and year are presented.

A report is compiled showing actual operation and downtime hours for each analysed unit (boiler, turbine, economizer).

12

Boiler Design Values Tracking Module

Data collection software Dween Data Collector is configured for the additional data collection from the fuel tracking/weighing system.

The boiler energy balance calculation module is periodically calibrated based on the received data.

Data of delivered biomass and other calculated indicators are included in reports.

13

Fuel tracking system integration

Data collection software Dween Data Collector is configured for the additional data collection from the fuel tracking/weighing system.

The boiler energy balance calculation module is periodically calibrated based on the received data.

Data of delivered biomass and other calculated indicators are included in reports.

14

Boiler Load Forecasting Module

An algorithm is prepared that calculates the forecast of boiler load 24 hours ahead.

Forecast data is presented in a periodic report in the user interface.

Advanced Package

08

Automatic Control Module

Calculated optimal control recommendations (Set Points) are sent directly into the control system without human intervention.

Recommendations are sent at needed frequency for the required control parameters.



Advanced Package

09

Automatic Control Module

An algorithm is prepared that calculates the balance of the boiler water system, evaluating returning condensate, prepared water, tank level fluctuations, and produced steam.

Balance results are available in a separate Dween Dashboard.

Balance results are continuously monitored, and staff are informed via email or SMS about any deviation that would indicate equipment malfunction.




Advanced Package

10

Boiler Long-Term Performance Monitoring Module

An algorithm is prepared calculating the efficiency of heat transfer across surfaces (reduced boiler efficiency).

An algorithm is prepared evaluating the deterioration of hydraulic pipeline properties



Advanced Package


11

Boiler Operation Availability Module

Based on agreed terms, the operating status of the boiler, turbine, economizers (operating/not operating) is tracked.

Operation status reports for the day, month, and year are presented.

A report is compiled showing actual operation and downtime hours for each analysed unit (boiler, turbine, economizer).



Advanced Package

12

Boiler Design Values Tracking Module

In the separate Dween Dashboard, boiler design and their corresponding measured or calculated values.

Staff are informed via email about deviations from design values.

Vanduo

	Esama	Projektinė
Katilo našumas	7.72 MW	8.05 MW
Antrinio oro slėgis		948.77 kPa
Tretinio oro slėgis		0.30 kPa
Vandens srautas per katilą		100.84 m ³ /h
Vandens temperatūra iš tinklų	45.65 °C	38.53 °C
Vandens temperatūra į katilą (prieš recirkuliaciją)		46.35 °C
Katilo recirkuliacinio siurblio sukimosi dažnis	91.84 %	47.12 %
Vandens temperatūra iš katilo	113.24 °C	115.00 °C
Vandens slėgis prieš katilą	7.39 bar	6.53 bar
Vandens slėgis po katilo	6.57 bar	5.73 bar

Pakura

	Esama	Projektinė
1 zonos ardymo temperatūra	220.52 °C	225.59 °C
2 zonos ardymo temperatūra	84.78 °C	72.45 °C
3 zonos ardymo temperatūra	44.32 °C	47.65 °C
Trauka pakuroje	-76.31 Pa	-105.00 Pa
Dūmsiurblio sukimosi dažnis	50.46 %	52.57 %
Recirkuliacijos dūmsiurblio sukimosi dažnis	44.02 %	75.00 %
Pakuros temperatūra	927.61 °C	555.25 °C

Kuras

	Esama	Projektinė
Kuro drėgmė	47.02 %	39.90 %
Kuro pelningumas		0.82 %
Kaloringumas	1656.02 kcal/kg	2443.00 kcal/kg
Kaloringumas	1.95 MW/tn	2.84 kWh/kg
Kuro sunaudojimas	4.92 tn/h	3.38 tn/h

Dūmai

	Esama	Projektinė
Dūmų temperatūra už pakuros (prieš katilą)	737.04 °C	699.49 °C
Dūmų temperatūra už katilo	188.87 °C	194.80 °C
O ₂ už katilo	6.68 O ₂ %	6.87 %
CO ₂ už katilo		11.93 %
CO už katilo		57.39 mg/m ³
NO _x už katilo		294.84 mg/m ³
Oro pertekliaus koeficientas	1.55	1.49

Oras

	Esama	Projektinė
Pirminio oro kiekis į 1 zoną ardymo	53.42 %	43.52 %
Pirminio oro srautas į 1 zoną ardymo	10.82 m ³ /min	8.66 m ³ /min
Pirminio oro kiekis į 2 zoną ardymo	44.62 %	36.87 %
Pirminio oro srautas į 2 zoną ardymo	13.19 m ³ /min	11.26 m ³ /min
Pirminio oro kiekis į 3 zoną ardymo	31.41 %	28.17 %
Pirminio oro srautas į 3 zoną ardymo	7.45 m ³ /min	7.25 m ³ /min
Antrinio oro ventiliatoriaus sukimosi dažnis	38.61 %	60.72 %
Tretinio oro ventiliatoriaus sukimosi dažnis	56.82 %	49.50 %
Oro temperatūra prieš ventiliatorius	2.46 °C	25.00 °C

Skaičiavimai

	Esama	Projektinė
Z reikšmė		7.19
Šilumos nuostoliai su išeinančiais dūmais	15.05 %	12.20 %
Šilumos nuostoliai dėl cheminio nesudegimo		0.50 %
Šilumos nuostoliai dėl mechaninio nesudegimo		1.00 %
Šilumos nuostoliai į aplinką	1.83 %	2.26 %
Šilumos nuostoliai su pelenais	0.34 %	0.10 %
NVK	83.76 %	83.95 %
Lyginamasis kuro sunaudojimas 1 MWh pagaminti	0.61 tn/MW	0.42 tn/MW
Lyginamasis naftos ekvivalento sunaudojimas 1 MWh pagaminti	102.66 kgne/MW	102.47 kgne/MW

Advanced Package


13

Fuel tracking system integration

Data collection software Dween Data Collector is configured for the additional data collection from the fuel tracking/weighing system.

The boiler energy balance calculation module is periodically calibrated based on the received data.

Data of delivered biomass and other calculated indicators are included in reports.




Advanced Package

14


Boiler Load Forecasting Module

An algorithm is prepared that calculates the forecast of boiler load 24 hours ahead.

Forecast data is presented in a periodic report in the user interface.



DWEEN Boiler



Technological
Process Perfection for
Biomass Power Plant

+37063516380

info@dween.com

dween.com